



Examination Report

This is to certify that the product listed below conforms to the requirements of the
Pressure Equipment (Safety) Regulations 2016
Schedule 1A Module A2

Certificate Number	HPIUK-P1143-T006-I-01-00	Next Surveillance Due	15-Jan-2023
Date of Issue	26-Jul-2022		
Manufacturer (or Authorised Representative)	AERMEC S.p.A. Via Roma 44, 37040 Bevilacqua (VR) Italy		

Equipment Description / Model	Air handling units models ENERGY and SPL; Roof-top units models RTX and RTY.
--------------------------------------	---

Pressure Range (bar)	Max PS=42
Temperature Range (°C)	-20 to 105

Report Reference	HPIUK-P1143-T006-1; 56648/19
-------------------------	------------------------------

This Report is valid in the United Kingdom.

This Report has been issued by **HPi Verification Services Ltd.** which is an **Approved Body** according to the provisions of the **Pressure Equipment (Safety) Regulations 2016 (Approved Body number 1521)**.

This Report is issued following the assessment of a representative example or examples of the Pressure Equipment submitted in accordance with the provisions of the above regulations. The **UKCA Mark** may be affixed to the Pressure Equipment once the 'declaration of conformity' has been signed by the responsible person.

Quality Director

Technical Director



Check this certificate is genuine

The manufacturer of the equipment to which this report applies must inform **HPi Verification Services Ltd.** of any proposed changes that could affect any of the assessed **Essential Safety Requirements**. Failure to do this will invalidate the report.



UK Approved Body No. 1521

Company registered in England #7217086

© HPi Verification Services Ltd. 2014

Tel +44 1491 822818

Email enquiries@hpivs.com

www.hpivs.com

HPi Verification Services Ltd.

The Manor House

Howbery Park, Wallingford

OX10 8BA, United Kingdom